



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.3	44.0	1.68		Y
3	8.0	----	1.62		Y
4	7.9	40.0	1.54		Y
5	8.0	----	1.61		Y
6	8.1	40.0	1.65		Y
7	----	----	----		----
8	----	----	----		----
9	7.9	43.0	1.43		Y
10	7.8	----	1.36		Y
11	7.7	42.0	1.36		Y
12	7.9	----	1.39		Y
13	8.3	41.0	1.38		Y
14	----	----	----		----
15	----	----	----		----
16	8.3	40.0	1.35		Y
17	8.3	----	1.37		Y
18	8.3	40.0	1.33		Y
19	8.4	----	1.36		Y
20	8.3	40.0	1.33		Y
21	----	----	----		----
22	----	----	----		----
23	8.3	41.0	1.36		Y
24	8.3	----	1.39		Y
25	8.3	66.0	1.33		Y
26	8.5	----	1.39		Y
27	8.5	62.0	1.33		Y
28	----	----	----		----
29	----	----	----		----
30	8.2	58.0	1.31		Y
31	8.3	----	1.36		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: March 2026
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter as set by State:**

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: April 1, 2026