



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.0	41.0	1.76		Y
2	----	----	----		----
3	----	----	----		----
4	8.0	40.0	1.68		Y
5	8.1	----	1.93		Y
6	8.1	40.0	2.12		Y
7	8.0	----	1.40		Y
8	8.0	41.0	1.55		Y
9	----	----	----		----
10	----	----	----		----
11	8.0	40.0	1.62		Y
12	8.1	----	2.20		Y
13	8.0	40.0	2.12		Y
14	8.0	----	1.99		Y
15	8.0	39.0	1.90		Y
16	----	----	----		----
17	----	----	----		----
18	8.1	41.0	1.76		Y
19	8.0	----	2.36		Y
20	8.1	41.0	2.09		Y
21	8.1	----	2.08		Y
22	8.1	43.0	1.72		Y
23	----	----	----		----
24	----	----	----		----
25	7.9	38.0	1.69		Y
26	7.9	----	1.72		Y
27	8.0	39.0	2.20		Y
28	8.0	----	2.20		Y
29	8.0	40.0	2.07		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** January 2021  
*Month/Year*

**Number of excursions during this month :** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO <sub>4</sub>	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>( )</i>

**Print Name:** Ryan A. Sherman

**Signature:**

**Date:** February 1, 2021