



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.2	47.0	1.79		Y
2	8.2	----	1.64		Y
3	8.1	46.0	1.68		Y
4	8.2	----	1.49		Y
5	8.1	45.0	1.52		Y
6	----	----	----		----
7	----	----	----		----
8	8.1	44.0	1.56		Y
9	8.1	----	1.63		Y
10	8.1	42.0	1.58		Y
11	8.1	----	1.59		Y
12	8.2	43.0	1.49		Y
13	----	----	----		----
14	----	----	----		----
15	8.1	44.0	1.68		Y
16	8.1	----	1.72		Y
17	8.1	43.0	1.69		Y
18	8.1	----	1.76		Y
19	8.1	44.0	1.74		Y
20	----	----	----		----
21	----	----	----		----
22	8.1	43.0	1.69		Y
23	8.1	----	1.59		Y
24	8.2	42.0	1.65		Y
25	8.3	----	1.88		Y
26	8.3	44.0	1.79		Y
27	----	----	----		----
28	----	----	----		----
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: February 2021
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: Ryan A. Sherman

Date: March 1, 2021

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>