



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	42.0	1.49		Y
2	7.9	----	1.40		Y
3	7.9	40.0	1.43		Y
4	7.9	----	1.44		Y
5	8.0	41.0	1.54		Y
6	----	----	----		----
7	----	----	----		----
8	8.0	43.0	1.57		Y
9	8.0	----	1.52		Y
10	8.0	44.0	1.51		Y
11	8.0	----	2.12		Y
12	8.0	46.0	2.07		Y
13	----	----	----		----
14	----	----	----		----
15	8.1	53.0	1.76		Y
16	8.2	45.0	1.32		Y
17	8.2	45.0	1.35		Y
18	8.3	----	1.36		Y
19	8.4	44.0	1.34		Y
20	----	----	----		----
21	----	----	----		----
22	----	----	----		----
23	8.4	44.0	1.65		Y
24	8.3	44.0	1.62		Y
25	8.3	----	1.63		Y
26	8.3	45.0	2.08		Y
27	----	----	----		----
28	----	----	----		----
29	8.2	39.0	2.20		Y
30	8.3	----	2.18		Y
31	8.2	42.0	2.09		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: March 1
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: Ryan A. S.

Date: April 1, 2021

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>