



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.3	44.0	1.99		Y
2	8.4	43.0	1.89		Y
3	----	----	----		----
4	----	----	----		----
5	8.2	44.0	1.67		Y
6	8.2	----	1.59		Y
7	8.2	43.0	1.63		Y
8	----	----	----		----
9	8.2	44.0	1.76		Y
10	----	----	----		----
11	----	----	----		----
12	8.1	45.0	1.61		Y
13	8.2	----	2.20		Y
14	8.1	44.0	2.12		Y
15	8.2	----	2.00		Y
16	8.0	43.0	1.87		Y
17	----	----	----		----
18	----	----	----		----
19	8.1	44.0	1.69		Y
20	8.1	----	1.99		Y
21	8.0	43.0	2.20		Y
22	8.1	----	2.19		Y
23	8.0	42.0	2.20		Y
24	----	----	----		----
25	----	----	----		----
26	8.1	42.0	2.19		Y
27	8.2	----	2.20		Y
28	8.1	44.0	2.09		Y
29	8.1	----	2.00		Y
30	8.1	43.0	1.79		Y
31	----	----	----		----
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** April 2021  
*Month/Year*

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality  
Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	<i>(Alkalinity)</i>
PO <sub>4</sub>	<b>1.3 mg/L</b>	<i>(Orthophosphate)</i>
Other	-----	<i>( )</i>

**Print Name:** Ryan A. SHERMAN

**Signature:** *Ryan A. Sherman*

**Date:** May 3, 2021

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>  
 Page 1 of 2