



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	----	----	----		----
2	----	----	----		----
3	8.1	43.0	1.51		Y
4	8.1	----	2.20		Y
5	8.1	44.0	2.20		Y
6	8.2	----	2.12		Y
7	8.1	44.0	2.09		Y
8	----	----	----		----
9	----	----	----		----
10	8.1	42.0	1.97		Y
11	8.1	----	1.79		Y
12	8.2	43.0	1.99		Y
13	8.1	----	1.82		Y
14	8.2	43.0	1.98		Y
15	----	----	----		----
16	----	----	----		----
17	8.2	44.0	1.62		Y
18	8.2	----	1.66		Y
19	8.1	43.0	1.59		Y
20	8.1	----	1.62		Y
21	8.1	44.0	1.76		Y
22	----	----	----		----
23	----	----	----		----
24	8.2	43.0	1.69		Y
25	8.2	----	1.68		Y
26	8.1	44.0	2.20		Y
27	8.1	----	2.34		Y
28	8.2	47.0	2.30		Y
29	----	----	----		----
30	----	----	----		----
31	8.2	49.0	2.17		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** May 2021  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	( )

**Print Name:** Ryan A. Sherman

**Signature:**

**Date:** June 1, 2021