



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.1	----	1.32		Y
2	8.2	53.0	1.31		Y
3	8.1	----	1.36		Y
4	8.1	52.0	1.40		Y
5	----	----	----		----
6	----	----	----		----
7	8.2	45.0	1.46		Y
8	8.2	----	1.59		Y
9	8.3	49.0	1.73		Y
10	8.2	----	1.65		Y
11	8.4	32.0	1.39		Y
12	----	----	----		----
13	----	----	----		----
14	8.1	43.0	1.54		Y
15	8.0	----	1.48		Y
16	8.1	44.0	1.52		Y
17	8.2	----	1.59		Y
18	8.2	43.0	1.52		Y
19	----	----	----		----
20	----	----	----		----
21	8.5	46.0	1.61		Y
22	8.5	----	1.68		Y
23	8.2	42.0	1.59		Y
24	8.4	----	1.59		Y
25	8.2	40.0	1.44		Y
26	----	----	----		----
27	----	----	----		----
28	8.2	63.0	1.79		Y
29	7.8	----	1.97		Y
30	8.1	62.0	1.51		Y
31	----	----	----		----
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** June 2021  
Month/Year

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality  
Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	<i>(Alkalinity)</i>
PO <sub>4</sub>	<b>1.3 mg/L</b>	<i>(Orthophosphate)</i>
Other	-----	<i>( )</i>

**Print Name:** Ryan A. Sherman

**Signature:** *Ryan A. Sherman*

**Date:** July 1, 2021