



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.2	----	1.51		Y
2	8.0	49.0	1.54		Y
3	----	----	----		----
4	----	----	----		----
5	8.1	48.0	1.61		Y
6	8.1	----	1.59		Y
7	8.1	49.0	1.57		Y
8	8.2	----	1.66		Y
9	8.2	50.0	1.78		Y
10	----	----	----		----
11	----	----	----		----
12	8.1	49.0	1.51		Y
13	8.0	----	1.38		Y
14	8.1	66.0	2.29		Y
15	8.2	----	2.31		Y
16	8.2	64.0	2.07		Y
17	----	----	----		----
18	----	----	----		----
19	8.1	56.0	1.36		Y
20	8.1	----	1.42		Y
21	8.1	57.0	1.50		Y
22	8.0	----	1.31		Y
23	7.9	50.0	1.42		Y
24	----	----	----		----
25	----	----	----		----
26	7.8	50.0	1.44		Y
27	7.9	----	1.52		Y
28	7.9	50.0	1.39		Y
29	7.9	----	1.61		Y
30	7.9	51.0	1.59		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: July 2021
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan Sherman

Signature:

Date: August 2, 2021