



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	----	----	----		----
2	7.7	44.0	1.38		Y
3	7.8	----	1.32		Y
4	7.9	45.0	1.39		Y
5	7.7	----	1.45		Y
6	7.8	47.0	1.59		Y
7	----	----	----		----
8	----	----	----		----
9	7.9	50.0	1.44		Y
10	7.9	----	1.51		Y
11	7.7	54.0	1.49		Y
12	7.8	----	1.55		Y
13	7.8	53.0	1.64		Y
14	----	----	----		----
15	----	----	----		----
16	7.8	59.0	1.48		Y
17	8.0	----	1.32		Y
18	7.9	57.0	1.41		Y
19	7.9	----	1.50		Y
20	8.0	58.0	1.49		Y
21	----	----	----		----
22	----	----	----		----
23	7.9	67.0	1.41		Y
24	7.7	----	1.38		Y
25	7.8	60.0	1.32		Y
26	7.8	----	1.42		Y
27	7.9	61.0	1.49		Y
28	----	----	----		----
29	----	----	----		----
30	7.9	45.0	1.44		Y
31	7.9	----	1.46		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** August 2021  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	(_____)

**Print Name:** Ryan A. Sherman

**Signature:** Ryan A. Sherman

**Date:** September 1, 2021