



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	7.8	65.0	1.52		Y
2	7.7	----	1.57		Y
3	7.8	65.0	1.42		Y
4	----	----	----		----
5	----	----	----		----
6	7.9	65.0	1.42		Y
7	7.8	----	1.36		Y
8	7.9	65.0	1.36		Y
9	7.8	----	1.41		Y
10	7.8	59.0	2.74		Y
11	----	----	----		----
12	----	----	----		----
13	7.7	55.0	1.88		Y
14	7.7	----	1.90		Y
15	7.5	63.0	1.32		Y
16	7.6	----	1.41		Y
17	7.6	63.0	1.31		Y
18	----	----	----		----
19	----	----	----		----
20	7.6	59.0	1.31		Y
21	7.7	----	1.33		Y
22	7.5	67.0	1.32		Y
23	7.5	54.0	1.31		Y
24	7.7	52.0	1.33		Y
25	----	----	----		----
26	----	----	----		----
27	7.5	48.0	1.34		Y
28	7.7	----	1.64		Y
29	7.7	40.0	1.37		Y
30	7.8	----	1.35		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** September 2021  
Month/Year

**Number of excursions during this month :** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	(_____)

**Print Name:** Ryan A. Sherman

**Signature:** \_\_\_\_\_

**Date:** September 30, 2021