



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.0	50.0	1.32		Y
2	----	----	----		----
3	----	----	----		----
4	8.1	42.0	1.43		Y
5	8.0	----	1.64		Y
6	8.1	47.0	1.57		Y
7	8.2	----	1.44		Y
8	8.3	53.0	1.43		Y
9	----	----	----		----
10	----	----	----		----
11	8.2	55.0	1.50		Y
12	8.2	----	1.49		Y
13	8.1	55.0	1.56		Y
14	8.1	----	1.44		Y
15	8.1	52.0	1.64		Y
16	----	----	----		----
17	----	----	----		----
18	8.1	50.0	1.52		Y
19	8.1	----	1.56		Y
20	8.0	56.0	1.45		Y
21	8.1	----	1.62		Y
22	8.0	54.0	1.67		Y
23	----	----	----		----
24	----	----	----		----
25	8.0	50.0	1.44		Y
26	8.0	----	1.50		Y
27	7.9	54.0	1.47		Y
28	8.0	----	1.48		Y
29	7.9	45.0	1.44		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: October 2021
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: November 1, 2021