



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | PO ₄ | Other | Y/N |
|----------------------------|-------|-------|-----------------|-------|----------|
| 1 | 7.9 | 54.0 | 2.20 | | Y |
| 2 | 7.9 | ----- | 2.12 | | Y |
| 3 | 8.0 | 52.0 | 2.09 | | Y |
| 4 | 7.9 | ----- | 2.01 | | Y |
| 5 | 7.8 | 50.0 | 1.89 | | Y |
| 6 | ----- | ----- | ----- | | ----- |
| 7 | ----- | ----- | ----- | | ----- |
| 8 | 7.8 | 49.0 | 1.95 | | Y |
| 9 | 7.9 | ----- | 1.96 | | Y |
| 10 | 7.9 | 54.0 | 2.34 | | Y |
| 11 | 7.9 | ----- | 2.29 | | Y |
| 12 | 8.0 | 51.0 | 2.17 | | Y |
| 13 | ----- | ----- | ----- | | ----- |
| 14 | ----- | ----- | ----- | | ----- |
| 15 | 8.0 | 50.0 | 1.99 | | Y |
| 16 | 7.7 | ----- | 1.56 | | Y |
| 17 | 7.7 | 50.0 | 1.59 | | Y |
| 18 | 7.7 | ----- | 1.56 | | Y |
| 19 | 7.9 | 50.0 | 1.64 | | Y |
| 20 | ----- | ----- | ----- | | ----- |
| 21 | ----- | ----- | ----- | | ----- |
| 22 | 7.9 | 39.0 | 1.58 | | Y |
| 23 | 8.4 | ----- | 1.55 | | Y |
| 24 | 7.9 | 39.0 | 1.51 | | Y |
| 25 | 8.0 | ----- | 1.59 | | Y |
| 26 | 8.0 | 40.0 | 1.68 | | Y |
| 27 | ----- | ----- | ----- | | ----- |
| 28 | ----- | ----- | ----- | | ----- |
| 29 | 7.8 | 36.0 | 1.54 | | Y |
| 30 | 7.8 | ----- | 1.62 | | Y |
| 31 | ----- | ----- | ----- | | ----- |
| (No=N=Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: November 2021

Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

| | | |
|-----------------|-----------------|-------------------------|
| pH | 7.5 | |
| Alk | 25 mg/l | <i>(Alkalinity)</i> |
| PO ₄ | 1.3 mg/L | <i>(Orthophosphate)</i> |
| Other | ----- | <i>()</i> |

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: December 1, 2021