



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	7.9	36.0	1.63		Y
2	7.9	----	1.69		Y
3	8.0	39.0	1.66		Y
4	----	----	----		----
5	----	----	----		----
6	8.0	33.0	1.61		Y
7	8.0	----	1.60		Y
8	----	----	----		----
9	7.7	29.0	2.20		Y
10	7.8	30.0	2.18		Y
11	----	----	----		----
12	----	----	----		----
13	7.8	30.0	1.62		Y
14	7.9	----	1.65		Y
15	7.9	31.0	1.76		Y
16	----	----	----		----
17	8.0	32.0	1.79		Y
18	8.0	32.0	1.81		Y
19	----	----	----		----
20	7.9	33.0	1.58		Y
21	7.8	----	1.42		Y
22	7.8	32.0	1.47		Y
23	8.0	----	1.50		Y
24	8.1	36.0	1.62		Y
25	----	----	----		----
26	----	----	----		----
27	8.0	37.0	1.59		Y
28	8.0	----	1.79		Y
29	8.0	35.0	1.81		Y
30	8.0	----	1.35		Y
31	8.1	36.0	1.41		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** December 2021  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	(_____)

**Print Name:** Ryan A. Sherman

**Signature:**

**Date:** January 3, 2022

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>