



Lead & Copper Rule Corrosion Control

| Day | pH | Alk | PO ₄ | Other | Y/N |
|----------------------------|------|------|-----------------|-------|----------|
| 1 | ---- | ---- | ---- | | ---- |
| 2 | ---- | ---- | ---- | | ---- |
| 3 | 8.1 | 38.0 | 1.77 | | Y |
| 4 | 8.1 | ---- | 1.99 | | Y |
| 5 | 8.0 | 36.0 | 1.68 | | Y |
| 6 | 8.1 | ---- | 1.77 | | Y |
| 7 | 8.1 | 39.0 | 1.69 | | Y |
| 8 | ---- | ---- | ---- | | ---- |
| 9 | ---- | ---- | ---- | | ---- |
| 10 | 8.0 | 37.0 | 2.20 | | Y |
| 11 | 8.1 | ---- | 2.12 | | Y |
| 12 | 8.1 | 44.0 | 1.31 | | Y |
| 13 | 8.1 | ---- | 1.56 | | Y |
| 14 | 8.2 | 45.0 | 1.63 | | Y |
| 15 | ---- | ---- | ---- | | ---- |
| 16 | ---- | ---- | ---- | | ---- |
| 17 | 8.1 | 43.0 | 1.64 | | Y |
| 18 | 8.3 | ---- | 1.68 | | Y |
| 19 | 8.1 | 33.0 | 1.59 | | Y |
| 20 | 8.0 | ---- | 1.66 | | Y |
| 21 | 8.1 | 38.0 | 1.72 | | Y |
| 22 | ---- | ---- | ---- | | ---- |
| 23 | ---- | ---- | ---- | | ---- |
| 24 | 8.1 | 40.0 | 1.79 | | Y |
| 25 | 8.1 | ---- | 1.84 | | Y |
| 26 | 8.2 | 42.0 | 1.77 | | Y |
| 27 | 8.1 | ---- | 1.84 | | Y |
| 28 | 8.0 | 41.0 | 1.79 | | Y |
| 29 | ---- | ---- | ---- | | ---- |
| 30 | ---- | ---- | ---- | | ---- |
| 31 | 8.0 | 41.0 | 1.31 | | Y |
| (No=N=Excursion) Total N's | | | | | 0 |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

| | |
|-----------------------|--|
| System Name: | <u>Myrtle Point, City of</u> |
| Entry Point: | <u>EP-A</u> |
| Sample Period: | <u>January 2022</u> <i>Month/Year</i> |

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

| | | |
|-----------------|-----------------|-------------------------|
| pH | 7.5 | |
| Alk | 25 mg/l | <i>(Alkalinity)</i> |
| PO ₄ | 1.3 mg/L | <i>(Orthophosphate)</i> |
| Other | ----- | <i>(_____)</i> |

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: February 2, 2022