



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	7.9	----	1.31		Y
2	7.9	41.0	1.30		Y
3	7.8	----	1.36		Y
4	7.6	37.0	1.33		Y
5	----	----	----		----
6	----	----	----		----
7	7.8	33.0	1.32		Y
8	7.9	34.0	1.35		Y
9	8.0	46.0	1.32		Y
10	7.8	32.0	1.31		Y
11	7.7	27.0	1.38		Y
12	----	----	----		----
13	----	----	----		----
14	7.8	36.0	1.40		Y
15	7.9	----	1.41		Y
16	8.0	38.0	1.54		Y
17	8.0	----	1.59		Y
18	8.0	39.0	1.76		Y
19	----	----	----		----
20	----	----	----		----
21	8.0	39.0	2.01		Y
22	8.1	----	2.07		Y
23	8.4	56.0	1.56		Y
24	8.4	----	1.40		Y
25	8.3	53.0	1.49		Y
26	----	----	----		----
27	----	----	----		----
28	8.2	38.0	1.34		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: February 2022
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: March 1, 2022