



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.1	----	1.33		Y
2	8.2	41.0	1.39		Y
3	8.2	----	1.78		Y
4	8.2	41.0	1.93		Y
5	----	----	----		----
6	----	----	----		----
7	8.1	33.0	1.37		Y
8	7.9	28.0	1.30		Y
9	8.0	30.0	1.36		Y
10	7.9	----	1.47		Y
11	7.9	33.0	1.57		Y
12	----	----	----		----
13	----	----	----		----
14	8.0	33.0	1.66		Y
15	8.1	----	1.72		Y
16	8.2	32.0	1.70		Y
17	8.2	----	1.65		Y
18	8.2	34.0	1.79		Y
19	----	----	----		----
20	----	----	----		----
21	7.8	30.0	1.49		Y
22	8.3	----	1.37		Y
23	8.2	32.0	1.41		Y
24	8.0	----	1.49		Y
25	7.9	42.0	1.85		Y
26	----	----	----		----
27	----	----	----		----
28	7.8	40.0	1.48		Y
29	7.9	----	1.54		Y
30	7.8	37.0	1.52		Y
31	7.9	----	1.56		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** March 2022  
Month/Year

**Number of excursions during this month :** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	( )

**Print Name:** Ryan A. Sherman

**Signature:** *Ryan A. Sherman*

**Date:** April 1, 2022