



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	7.8	39.0	1.52		Y
2	----	----	----		----
3	----	----	----		----
4	7.9	39.0	1.59		Y
5	7.9	----	1.63		Y
6	7.9	36.0	1.70		Y
7	7.7	----	1.87		Y
8	7.8	39.0	1.91		Y
9	----	----	----		----
10	----	----	----		----
11	7.9	41.0	2.16		Y
12	8.0	----	2.09		Y
13	8.0	35.0	1.57		Y
14	8.0	----	1.34		Y
15	8.1	35.0	1.51		Y
16	----	----	----		----
17	----	----	----		----
18	8.0	31.0	1.56		Y
19	8.0	----	1.61		Y
20	8.1	33.0	1.68		Y
21	8.1	----	1.72		Y
22	8.2	36.0	1.68		Y
23	----	----	----		----
24	----	----	----		----
25	8.1	30.0	1.66		Y
26	8.0	----	1.59		Y
27	8.0	39.0	1.67		Y
28	7.9	----	1.65		Y
29	7.9	37.0	1.72		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: April 2022
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature:

Date: May 2, 2022

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2