



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	7.6	37.0	1.53		Y
3	7.7	----	2.12		Y
4	7.8	38.0	2.00		Y
5	7.9	----	1.76		Y
6	7.9	32.0	1.60		Y
7	----	----	----		----
8	----	----	----		----
9	8.1	38.0	1.79		Y
10	8.2	----	1.63		Y
11	8.4	39.0	1.76		Y
12	8.3	----	1.65		Y
13	8.0	30.0	1.39		Y
14	----	----	----		----
15	----	----	----		----
16	8.1	28.0	1.31		Y
17	8.1	----	1.36		Y
18	8.1	30.0	1.35		Y
19	8.1	----	1.59		Y
20	8.2	33.0	1.65		Y
21	----	----	----		----
22	----	----	----		----
23	7.7	30.0	1.41		Y
24	7.9	----	1.49		Y
25	7.9	32.0	1.57		Y
26	7.6	----	1.66		Y
27	7.7	31.0	1.71		Y
28	----	----	----		----
29	----	----	----		----
30	7.8	30.0	1.89		Y
31	7.9	----	1.93		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: May 2022
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan Sherman

Signature:

Date: June 1, 2022