



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	7.9	33.0	1.76		Y
2	7.8	----	1.63		Y
3	7.8	36.0	1.96		Y
4	----	----	----		----
5	----	----	----		----
6	7.6	30.0	1.56		Y
7	7.7	----	1.71		Y
8	7.8	38.0	1.48		Y
9	7.9	----	1.56		Y
10	7.9	39.0	1.63		Y
11	----	----	----		----
12	----	----	----		----
13	8.0	38.0	1.71		Y
14	8.0	----	1.75		Y
15	----	----	----		----
16	8.1	36.0	1.84		Y
17	8.1	----	1.91		Y
18	----	----	----		----
19	----	----	----		----
20	7.6	38.0	1.48		Y
21	7.7	----	1.51		Y
22	8.0	40.0	1.69		Y
23	8.1	----	1.72		Y
24	8.0	33.0	1.37		Y
25	----	----	----		----
26	----	----	----		----
27	8.0	46.0	1.60		Y
28	8.0	----	1.40		Y
29	8.0	46.0	1.56		Y
30	8.2	----	1.34		Y
31	----	----	----		----
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** June 2022  
*Month/Year*

**Number of excursions during this month :** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

### Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO <sub>4</sub>	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>( )</i>

**Print Name:** Ryan A. Sherman

**Signature:** *Ryan A. Sherman*

**Date:** July 4, 2022

Send to Drinking Water Program within 10 days after end of sampling period.  
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350  
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>