



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	42.0	1.48		Y
2	----	----	----		----
3	----	----	----		----
4	8.1	41.0	1.42		Y
5	8.1	----	1.32		Y
6	8.0	39.0	1.31		Y
7	8.1	----	1.33		Y
8	8.1	43.0	1.36		Y
9	----	----	----		----
10	----	----	----		----
11	8.1	43.0	1.43		Y
12	8.2	----	1.51		Y
13	----	----	----		----
14	8.3	44.0	1.50		Y
15	8.2	43.0	1.49		Y
16	----	----	----		----
17	----	----	----		----
18	7.9	42.0	1.38		Y
19	8.0	----	1.44		Y
20	8.1	44.0	1.49		Y
21	8.1	----	1.56		Y
22	8.1	47.0	1.59		Y
23	----	----	----		----
24	----	----	----		----
25	8.0	54.0	1.46		Y
26	7.9	----	1.38		Y
27	7.9	52.0	1.44		Y
28	8.0	----	1.59		Y
29	8.1	51.0	1.72		Y
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: July 2022
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter as set by State:**

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>()</i>

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: August 1, 2022

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>