



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	44.0	1.72		Y
2	8.0	----	1.64		Y
3	8.1	46.0	1.68		Y
4	8.0	----	1.53		Y
5	8.1	49.0	1.68		Y
6	----	----	----		----
7	----	----	----		----
8	7.9	54.0	1.73		Y
9	7.9	----	1.39		Y
10	7.9	55.0	1.45		Y
11	8.0	----	1.53		Y
12	8.0	54.0	1.55		Y
13	----	----	----		----
14	----	----	----		----
15	8.0	59.0	1.39		Y
16	7.8	----	1.69		Y
17	7.9	56.0	1.76		Y
18	7.9	----	1.84		Y
19	8.0	52.0	1.33		Y
20	----	----	----		----
21	----	----	----		----
22	8.0	55.0	1.49		Y
23	8.1	----	1.56		Y
24	8.1	54.0	1.68		Y
25	8.3	----	1.76		Y
26	8.1	50.0	1.73		Y
27	----	----	----		----
28	----	----	----		----
29	7.9	45.0	1.96		Y
30	7.9	----	1.79		Y
31	8.0	49.0	1.79		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: August 2022
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter as set by State:**

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: September 1, 2022