



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	----	1.77		Y
2	8.1	54.0	1.91		Y
3	----	----	----		----
4	----	----	----		----
5	8.1	55.0	1.99		Y
6	7.8	----	2.20		Y
7	7.8	54.0	2.10		Y
8	8.0	----	1.51		Y
9	8.0	58.0	1.79		Y
10	----	----	----		----
11	----	----	----		----
12	8.0	57.0	1.59		Y
13	8.0	72.0	1.35		Y
14	8.0	72.0	1.36		Y
15	8.2	----	1.39		Y
16	8.3	70.0	1.42		Y
17	----	----	----		----
18	----	----	----		----
19	8.1	61.0	1.65		Y
20	8.1	----	1.76		Y
21	8.0	59.0	1.81		Y
22	8.1	----	1.89		Y
23	8.1	60.0	1.51		Y
24	----	----	----		----
25	----	----	----		----
26	8.0	54.0	1.33		Y
27	8.0	----	1.39		Y
28	8.1	56.0	1.49		Y
29	8.1	----	1.49		Y
30	8.0	54.0	1.37		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: September 2022
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>(_____)</i>

Print Name: Ryan A. Sherman

Signature: 

Date: October 3, 2022

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2