



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	53.0	1.65		Y
2	8.0	48.0	1.64		Y
3	8.0	-----	1.66		Y
4	8.0	49.0	1.66		Y
5	-----	-----	-----		-----
6	-----	-----	-----		-----
7	7.8	47.0	1.68		Y
8	7.9	-----	1.72		Y
9	8.4	39.0	1.87		Y
10	8.3	-----	1.81		Y
11	8.4	35.0	1.79		Y
12	-----	-----	-----		-----
13	-----	-----	-----		-----
14	8.4	39.0	1.82		Y
15	8.4	-----	1.86		Y
16	8.4	41.0	1.98		Y
17	8.4	-----	2.11		Y
18	8.4	44.0	2.07		Y
19	-----	-----	-----		-----
20	-----	-----	-----		-----
21	8.3	43.0	1.96		Y
22	8.3	-----	1.90		Y
23	8.3	44.0	1.98		Y
24	8.2	-----	1.94		Y
25	8.3	43.0	1.83		Y
26	-----	-----	-----		-----
27	-----	-----	-----		-----
28	8.1	40.0	1.88		Y
29	8.2	-----	1.94		Y
30	8.2	42.0	1.90		Y
31	-----	-----	-----		-----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: November 2022
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: December 2, 2022

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2