



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	----	1.86		Y
2	7.6	33.0	1.98		Y
3	7.7	----	2.01		Y
4	----	----	----		----
5	7.8	37.0	2.07		Y
6	7.8	----	2.00		Y
7	7.9	39.0	1.96		Y
8	7.9	----	1.91		Y
9	7.9	41.0	1.87		Y
10	----	----	----		----
11	----	----	----		----
12	7.8	52.0	2.02		Y
13	7.9	----	2.06		Y
14	7.9	53.0	2.10		Y
15	8.0	----	2.05		Y
16	8.0	54.0	2.03		Y
17	8.0	----	1.97		Y
18	----	----	----		----
19	7.9	52.0	1.96		Y
20	7.8	----	1.78		Y
21	7.9	52.0	1.80		Y
22	7.9	----	1.81		Y
23	8.0	50.0	1.90		Y
24	----	----	----		----
25	----	----	----		----
26	8.0	50.0	1.87		Y
27	----	----	----		----
28	8.0	51.0	1.91		Y
29	8.1	----	1.94		Y
30	8.1	51.0	1.82		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: December 2022
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: January 3, 2023

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>