



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.1	50.0	1.81		Y
3	8.1	----	1.76		Y
4	8.1	49.0	1.82		Y
5	8.1	----	1.96		Y
6	8.1	49.0	2.01		Y
7	----	----	----		----
8	----	----	----		----
9	8.0	47.0	2.10		Y
10	8.1	----	2.13		Y
11	8.1	46.0	2.09		Y
12	8.2	----	2.06		Y
13	8.0	45.0	2.20		Y
14	----	----	----		----
15	----	----	----		----
16	7.9	42.0	2.01		Y
17	7.7	----	2.06		Y
18	7.8	40.0	2.09		Y
19	7.8	----	2.13		Y
20	7.9	42.0	2.17		Y
21	----	----	----		----
22	----	----	----		----
23	8.0	47.0	2.23		Y
24	8.0	----	2.20		Y
25	8.1	48.0	2.20		Y
26	8.1	----	2.20		Y
27	8.1	49.0	2.20		Y
28	----	----	----		----
29	----	----	----		----
30	8.2	50.0	2.20		Y
31	8.2	----	2.20		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of
Entry Point: EP-A
Sample Period: January 2023
Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman
Signature: *Ryan A. Sherman*
Date: February 1, 2023

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>