



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.1	50.0	2.20		Y
2	8.2	----	2.20		Y
3	8.2	51.0	2.17		Y
4	----	----	----		----
5	----	----	----		----
6	8.3	52.0	2.20		Y
7	8.2	----	2.20		Y
8	8.0	51.0	2.19		Y
9	7.8	----	2.20		Y
10	7.9	50.0	2.00		Y
11	----	----	----		----
12	----	----	----		----
13	7.9	55.0	1.94		Y
14	8.0	----	2.04		Y
15	8.0	54.0	2.09		Y
16	8.1	----	2.11		Y
17	8.1	53.0	2.07		Y
18	----	----	----		----
19	----	----	----		----
20	8.1	53.0	2.10		Y
21	7.9	----	1.90		Y
22	7.9	53.0	1.97		Y
23	8.0	----	2.03		Y
24	8.0	52.0	2.11		Y
25	----	----	----		----
26	----	----	----		----
27	8.1	53.0	2.20		Y
28	8.2	----	2.20		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: 2023
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: March 1, 2023