



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.0	50.0	2.01		Y
2	8.1	-----	2.04		Y
3	8.1	50.0	2.09		Y
4	7.8	-----	1.77		Y
5	7.8	50.0	1.84		Y
6	-----	-----	-----		-----
7	-----	-----	-----		-----
8	7.8	48.0	1.89		Y
9	7.7	-----	1.77		Y
10	7.8	53.0	1.65		Y
11	7.9	-----	1.68		Y
12	7.9	50.0	1.69		Y
13	-----	-----	-----		-----
14	-----	-----	-----		-----
15	7.6	53.0	1.65		Y
16	7.7	-----	1.76		Y
17	7.6	53.0	1.70		Y
18	7.6	-----	1.71		Y
19	7.7	52.0	1.77		Y
20	-----	-----	-----		-----
21	-----	-----	-----		-----
22	7.8	53.0	1.81		Y
23	7.9	-----	1.76		Y
24	8.0	54.0	1.79		Y
25	7.9	-----	1.88		Y
26	7.9	59.0	1.91		Y
27	-----	-----	-----		-----
28	-----	-----	-----		-----
29	8.0	58.0	1.92		Y
30	8.1	-----	2.07		Y
31	8.0	58.0	1.59		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: 2023
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>()</i>

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: June 1, 2023