



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	7.8	----	1.76		Y
2	7.8	50.0	1.81		Y
3	----	----	----		----
4	----	----	----		----
5	7.9	50.0	1.81		Y
6	7.9	----	1.88		Y
7	8.0	51.0	1.96		Y
8	8.0	----	1.99		Y
9	8.1	56.0	2.02		Y
10	----	----	----		----
11	----	----	----		----
12	8.1	59.0	2.10		Y
13	8.1	----	2.01		Y
14	8.1	58.0	2.06		Y
15	7.9	----	1.70		Y
16	7.9	57.0	1.76		Y
17	----	----	----		----
18	----	----	----		----
19	8.0	56.0	1.79		Y
20	8.0	----	1.88		Y
21	----	----	----		----
22	8.1	54.0	1.91		Y
23	8.2	55.0	1.97		Y
24	----	----	----		----
25	----	----	----		----
26	8.4	58.0	2.11		Y
27	8.4	----	2.07		Y
28	----	----	----		----
29	8.3	56.0	1.79		Y
30	8.2	57.0	1.82		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: 2023
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: July 3, 2023