



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	----	----	----		----
3	7.9	53.0	1.41		Y
4	8.0	----	1.44		Y
5	7.9	68.0	1.47		Y
6	7.9	----	1.50		Y
7	7.9	44.0	1.55		Y
8	----	----	----		----
9	----	----	----		----
10	7.8	47.0	2.20		Y
11	7.6	----	1.30		Y
12	7.7	45.0	2.00		Y
13	7.6	----	1.45		Y
14	7.5	43.0	1.31		Y
15	----	----	----		----
16	----	----	----		----
17	7.6	42.0	1.36		Y
18	7.7	----	1.36		Y
19	7.9	52.0	1.40		Y
20	7.9	----	1.50		Y
21	7.9	53.0	2.12		Y
22	----	----	----		----
23	----	----	----		----
24	8.0	53.0	2.20		Y
25	8.1	----	1.42		Y
26	8.2	57.0	2.40		Y
27	8.3	----	2.11		Y
28	8.2	54.0	2.01		Y
29	----	----	----		----
30	----	----	----		----
31	8.3	56.0	1.88		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: July 2023
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: *Ryan A. Sherman*

Date: August 1, 2023

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2