



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.0	----	2.11		Y
2	8.0	56.0	2.09		Y
3	7.8	----	2.20		Y
4	7.8	57.0	2.07		Y
5	----	----	----		----
6	----	----	----		----
7	7.9	54.0	2.01		Y
8	7.9	----	2.00		Y
9	7.6	60.0	1.51		Y
10	7.8	----	2.12		Y
11	7.8	60.0	2.12		Y
12	----	----	----		----
13	----	----	----		----
14	7.9	54.0	2.01		Y
15	7.9	----	2.00		Y
16	7.6	60.0	1.51		Y
17	7.8	----	2.12		Y
18	7.8	60.0	2.12		Y
19	----	----	----		----
20	----	----	----		----
21	7.6	60.0	1.81		Y
22	7.8	55.0	1.51		Y
23	7.8	56.0	1.48		Y
24	7.8	55.0	1.39		Y
25	7.9	54.0	1.93		Y
26	----	----	----		----
27	----	----	----		----
28	7.9	62.0	1.39		Y
29	8.0	----	1.78		Y
30	7.9	62.0	1.99		Y
31	7.7	----	1.50		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** 2023  
Month/Year

**Number of excursions during this month :** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*Addendum: Didn't Notice Typo when emailed on Friday leading to an excursion. While using 10 KEY accidentally hit 1.71 on 2023 (PO4)*

*For OHA use only It has been corrected on my end Thank you. Ryan A-S*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	( )

**Print Name:** Ryan A. Sherman

**Signature:** *Ryan A. Sherman*

**Date:** September 4, 2023