



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	----	----	----		----
2	8.0	53.0	2.11		Y
3	8.1	----	2.10		Y
4	7.6	50.0	1.60		Y
5	8.1	50.0	1.43		Y
6	7.7	45.0	1.41		Y
7	----	----	----		----
8	----	----	----		----
9	7.8	50.0	1.33		Y
10	8.0	48.0	1.41		Y
11	7.9	49.0	1.38		Y
12	8.4	48.0	1.30		Y
13	8.4	50.0	1.35		Y
14	----	----	----		----
15	----	----	----		----
16	8.4	53.0	1.34		Y
17	8.4	47.0	1.31		Y
18	8.0	47.0	1.46		Y
19	8.5	46.0	1.34		Y
20	8.4	47.0	1.33		Y
21	----	----	----		----
22	----	----	----		----
23	8.2	50.0	1.40		Y
24	8.1	----	1.44		Y
25	8.2	49.0	1.47		Y
26	8.0	----	1.93		Y
27	8.2	53.0	2.10		Y
28	----	----	----		----
29	----	----	----		----
30	8.1	52.0	2.09		Y
31	8.0	----	2.12		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00551**

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** 2023  
Month/Year

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*


**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO <sub>4</sub>	1.3 mg/L	(Orthophosphate)
Other	-----	( )

**Print Name:** Ryan Sherman

**Signature:** 

**Date:** November 1, 2023