



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	8.0	44.0	1.74		Y
2	8.0	----	1.76		Y
3	8.2	47.0	1.98		Y
4	----	----	----		----
5	----	----	----		----
6	8.3	49.0	1.96		Y
7	8.3	----	1.98		Y
8	8.4	51.0	1.84		Y
9	8.1	----	1.98		Y
10	8.2	52.0	1.99		Y
11	----	----	----		----
12	----	----	----		----
13	8.6	50.0	1.54		Y
14	8.5	----	1.56		Y
15	8.6	51.0	1.36		Y
16	8.6	----	1.42		Y
17	8.7	50.0	1.49		Y
18	----	----	----		----
19	----	----	----		----
20	8.8	51.0	1.56		Y
21	8.9	----	1.63		Y
22	8.8	50.0	1.68		Y
23	8.7	----	1.63		Y
24	8.8	52.0	1.68		Y
25	----	----	----		----
26	----	----	----		----
27	8.9	51.0	1.60		Y
28	9.0	----	1.69		Y
29	8.9	50.0	1.56		Y
30	8.8	----	1.61		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: 2023
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	<i>(Alkalinity)</i>
PO ₄	1.3 mg/L	<i>(Orthophosphate)</i>
Other	-----	<i>()</i>

Print Name: Ryan A Sherman

Signature: *Ryan A Sherman*

Date: December 1, 2023

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>