



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO <sub>4</sub>	Other	Y/N
1	8.2	50.0	1.64		Y
2	----	----	----		----
3	----	----	----		----
4	8.2	49.0	1.55		Y
5	8.2	----	1.63		Y
6	8.2	53.0	1.76		Y
7	8.0	----	1.65		Y
8	8.1	52.0	1.76		Y
9	8.1	----	1.70		Y
10	----	----	----		----
11	8.3	53.0	2.20		Y
12	8.4	----	2.07		Y
13	8.4	52.0	1.69		Y
14	8.3	----	1.60		Y
15	8.6	53.0	1.76		Y
16	----	----	----		----
17	----	----	----		----
18	8.2	50.0	1.59		Y
19	8.4	----	1.73		Y
20	8.3	51.0	1.96		Y
21	8.4	----	2.01		Y
22	8.4	50.0	2.16		Y
23	----	----	----		----
24	8.3	50.0	2.09		Y
25	----	----	----		----
26	8.4	50.0	2.11		Y
27	8.8	----	2.16		Y
28	8.7	55.0	2.10		Y
29	8.7	----	2.07		Y
30	----	----	----		----
31	8.7	58.0	2.09		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

### PWS ID: 41 00551

**System Name:** Myrtle Point, City of

**Entry Point:** EP-A

**Sample Period:** December 2023  
Month/Year

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.5</b>	
Alk	<b>25 mg/l</b>	(Alkalinity)
PO <sub>4</sub>	<b>1.3 mg/L</b>	(Orthophosphate)
Other	-----	( )

**Print Name:** Ryan A. Sheaman

**Signature:** [Signature]

**Date:** January 2, 2024