



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.7	53.0	1.97		Y
3	8.5	----	1.89		Y
4	8.4	30.0	1.31		Y
5	8.3	----	1.31		Y
6	8.4	36.0	1.49		Y
7	----	----	----		----
8	8.4	40.0	1.59		Y
9	8.4	----	1.61		Y
10	8.2	40.0	1.61		Y
11	7.9	----	1.57		Y
12	8.6	40.0	1.41		Y
13	----	----	----		----
14	----	----	----		----
15	8.5	42.0	1.64		Y
16	8.5	----	1.76		Y
17	8.5	43.0	1.89		Y
18	8.4	----	1.94		Y
19	8.4	43.0	1.96		Y
20	----	----	----		----
21	----	----	----		----
22	8.4	44.0	1.98		Y
23	8.4	----	1.87		Y
24	8.4	42.0	1.77		Y
25	8.4	----	1.79		Y
26	8.4	43.0	1.83		Y
27	----	----	----		----
28	----	----	----		----
29	8.2	40.0	1.99		Y
30	8.1	----	1.87		Y
31	8.1	42.0	1.94		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: January 2024
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature:

Date: February 1, 2024