



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	8.4	72.0	1.37		Y
3	8.5	----	1.33		Y
4	8.5	71.0	1.36		Y
5	8.7	----	2.17		Y
6	8.6	71.0	2.20		Y
7	----	----	----		----
8	----	----	----		----
9	8.5	74.0	1.61		Y
10	8.4	----	1.63		Y
11	8.4	68.0	1.68		Y
12	8.4	----	1.38		Y
13	8.5	68.0	1.40		Y
14	----	----	----		----
15	----	----	----		----
16	8.5	70.0	1.30		Y
17	8.6	----	1.33		Y
18	8.5	71.0	1.32		Y
19	8.6	----	1.46		Y
20	8.5	70.0	1.55		Y
21	----	----	----		----
22	----	----	----		----
23	8.5	71.0	1.68		Y
24	8.5	----	1.69		Y
25	8.4	70.0	1.72		Y
26	8.4	----	1.75		Y
27	8.4	70.0	1.82		Y
28	----	----	----		----
29	----	----	----		----
30	8.2	55.0	1.74		Y
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: September 2024
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	(_____)

Print Name: Ryan A. Sherman

Signature: 

Date: October 1, 2024

Send to Drinking Water Program within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 Website: <http://healthoregon.org/dwp/>
 Page 1 of 2