



Lead & Copper Rule Corrosion Control

Day	pH	Alk	PO ₄	Other	Y/N
1	----	----	----		----
2	----	----	----		----
3	8.6	47.0	2.20		Y
4	8.7	----	2.00		Y
5	8.6	46.0	1.95		Y
6	8.5	----	1.67		Y
7	8.3	43.0	1.59		Y
8	----	----	----		----
9	----	----	----		----
10	8.3	44.0	1.75		Y
11	8.4	----	1.86		Y
12	8.3	37.0	1.69		Y
13	8.4	----	1.74		Y
14	8.8	36.0	1.81		Y
15	----	----	----		----
16	----	----	----		----
17	8.4	38.0	2.00		Y
18	8.5	----	2.06		Y
19	8.4	39.0	2.09		Y
20	8.8	----	1.88		Y
21	8.8	49.0	1.96		Y
22	----	----	----		----
23	----	----	----		----
24	8.3	45.0	2.20		Y
25	8.4	----	2.20		Y
26	8.3	45.0	2.20		Y
27	8.2	----	2.20		Y
28	8.1	43.0	2.07		Y
29	----	----	----		----
30	----	----	----		----
31	----	----	----		----
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00551

System Name: Myrtle Point, City of

Entry Point: EP-A

Sample Period: February 2025
Month/Year

Number of excursions during this month : 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.5	
Alk	25 mg/l	(Alkalinity)
PO ₄	1.3 mg/L	(Orthophosphate)
Other	-----	()

Print Name: Ryan A. Sherman

Signature:

Date: March 3, 2025