

Day	pH	Alk	Phos	Other	Y/N
1	7.60				Y
2	7.65				Y
3	7.77				Y
4	7.75				Y
5	7.73				Y
6	7.74	33			Y
7	7.69				Y
8	7.61				Y
9	7.58				Y
10	7.59				Y
11	7.71				Y
12	7.80				Y
13	7.77				Y
14	7.80				Y
15	7.73				Y
16	7.77				Y
17	7.70				Y
18	7.74				Y
19	7.75				Y
20	7.68				Y
21	7.70				Y
22	7.69				Y
23	7.71				Y
24	7.68				Y
25	7.74				Y
26	7.75				Y
27	7.72				Y
28	7.68				Y
29	7.67				Y
30	7.69				Y
31	7.72				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Netarts Water District

Entry Point: Clear Well

Sample Period: July / 2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: MICHAEL SLUSSAGEN

Signature: [Signature]

Date: 8-3-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's