

Day	pH	Alk	Phos	Other	Y/N
1	7.69				Y
2	7.57				Y
3	7.70				Y
4	7.63				Y
5	7.58				Y
6	7.57				Y
7	7.61				Y
8	7.60				Y
9	7.73				Y
10	7.55				Y
11	7.75				Y
12	7.67				Y
13	7.72				Y
14	7.70				Y
15	7.67				Y
16	7.70				Y
17	7.59				Y
18	7.72				Y
19	7.85				Y
20	7.62				Y
21	7.67				Y
22	7.67				Y
23	7.65				Y
24	7.73				Y
25	7.67				Y
26	7.55				Y
27	7.59				Y
28	7.68				Y
29					Y
30					Y
31					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: NETARTS WATER DISTRICT

Entry Point: CLEARWELL / TREATMENT PLANT

Sample Period: 02/2022 FEBRUARY
(Month/Year)

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: TIM LYDA

Signature: [Signature]

Date: 3-3-22

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's