

Day	pH	Alk	Phos	Other	Y/N
1	7.51				Y
2	7.52				Y
3	7.53				Y
4	7.52				Y
5	7.54				Y
6	7.70				Y
7	7.91				Y
8	7.40				Y
9	7.63				Y
10	7.62				Y
11	7.59				Y
12	7.57				Y
13	7.61				Y
14	7.62				Y
15	7.43				Y
16	7.61				Y
17	7.81				Y
18	7.73				Y
19	7.71				Y
20	7.65				Y
21	7.63				Y
22	7.59				Y
23	7.58				Y
24	7.53				Y
25	7.55				Y
26	7.57				Y
27	7.75				Y
28	7.70				Y
29	7.72				Y
30	7.73				Y
31	7.70				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: NETARTS WATER DISTRICT

Entry Point: FIRST USER


Sample Period: MAY 2022  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH  

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: DAVID B HANCOCK

Signature: [Signature]

Date: 6/2/2022

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's