

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.70				Y
2	7.65				Y
3	7.70				Y
4	7.68				Y
5	7.71				Y
6	7.68				Y
7	7.73				Y
8	7.69				Y
9	7.76				Y
10	7.70				Y
11	7.71				Y
12	7.65				Y
13	7.68				Y
14	7.67				Y
15	7.66				Y
16	7.65				Y
17	7.65				Y
18	7.66				Y
19	7.70				Y
20	7.61				Y
21	7.70				Y
22	7.73				Y
23	7.74				Y
24	7.72				Y
25	7.74				Y
26	7.73				Y
27	7.73				Y
28	7.77				Y
29	7.58				Y
30	7.56				Y
31	7.63				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: METARTS WATER DISTRICT

Entry Point: FIRST USER

Sample Period: JULY 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.40

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DAVID B Stangock

Signature: [Signature]

Date: 8/01/2022

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's