

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 7.57 | | | | Y |
| 2 | 7.54 | | | | Y |
| 3 | 7.53 | | | | Y |
| 4 | 7.49 | | | | Y |
| 5 | 7.52 | | | | Y |
| 6 | 7.51 | | | | Y |
| 7 | 7.52 | | | | Y |
| 8 | 7.45 | | | | Y |
| 9 | 7.57 | | | | Y |
| 10 | 7.45 | | | | Y |
| 11 | 7.51 | | | | Y |
| 12 | 7.59 | | | | Y |
| 13 | 7.57 | | | | Y |
| 14 | 7.55 | | | | Y |
| 15 | 7.53 | | | | Y |
| 16 | 7.65 | | | | Y |
| 17 | 7.53 | | | | Y |
| 18 | 7.65 | | | | Y |
| 19 | 7.72 | | | | Y |
| 20 | 7.71 | | | | Y |
| 21 | 7.72 | | | | Y |
| 22 | 7.63 | | | | Y |
| 23 | 7.58 | | | | Y |
| 24 | 7.60 | | | | Y |
| 25 | 7.56 | | | | Y |
| 26 | 7.57 | | | | Y |
| 27 | 7.59 | | | | Y |
| 28 | 7.59 | | | | Y |
| 29 | 7.74 | | | | Y |
| 30 | 7.90 | | | | Y |
| 31 | 7.62 | | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: NETARTS WATER DISTRICT

Entry Point: WTP^A - CLEARWELL

Sample Period: 9/6/22 
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: DAVID HANCOCK
 Signature: *David Hancock*
 Date: 9/6/2022

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's