

Day	pH	Alk	Phos	Other	Y/N
1	7.69				N
2	7.62				N
3	7.77				N
4	7.78				N
5	7.80				N
6	7.78				Y
7	7.64				Y
8	7.69				Y
9	7.61				Y
10	7.46				Y
11	7.45				Y
12	7.46				Y
13	7.43				Y
14	7.52				Y
15	7.45				Y
16	7.50				Y
17	7.57				Y
18	7.56				Y
19	7.59				Y
20	7.77				Y
21	7.60				Y
22	7.60				Y
23	7.64				Y
24	7.65				Y
25	7.63				Y
26	7.63				Y
27	7.62				Y
28	7.61				Y
29	7.62				Y
30	7.64				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00556

System Name: NETARTS WATER DISTRICT

Entry Point: 1ST USER

Sample Period: SEPTEMBER / 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.4

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DAVID B Hancock

Signature: *David B Hancock*

Date: 10/5/2022

Send to DWP within 10 days after end of sampling period

No = N = Excursion) **Total N's** 0