

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.70				Y
2	7.68				Y
3	7.70				Y
4	7.71				Y
5	7.73				Y
6	7.75				Y
7	7.73				Y
8	7.70				Y
9	7.70				Y
10	7.69				Y
11	7.77				Y
12	7.74				Y
13	7.73				Y
14	7.73				Y
15	7.72				Y
16	7.72				Y
17	7.73				Y
18	7.74				Y
19	7.73				Y
20	7.70				Y
21	7.70				Y
22	7.71				Y
23	7.66				Y
24	7.66				Y
25	7.62				Y
26	7.72				Y
27	7.62				Y
28	7.64				Y
29	7.50				Y
30	7.52				Y
31	7.58				Y

No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: NETARTS WATER DISTRICT

Entry Point: FIRST USER

Sample Period: OCTOBER / 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: David Hancock

Signature: David Hancock

Date: 11/2/2022

Send to DWP within 10 days after end of sampling period