

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.43				Y
2	7.41				Y
3	7.49				Y
4	7.58				Y
5	7.53				Y
6	7.55				Y
7	7.63				Y
8	7.59				Y
9	7.34				N
10	7.35				N
11	7.38				N
12	7.36				N
13	7.49				Y
14	7.59				Y
15	7.53				Y
16	7.60				Y
17	7.67				Y
18	7.69				Y
19	7.73				Y
20	7.76				Y
21	7.64				Y
22	7.77				Y
23	7.75				Y
24	7.70				Y
25	7.79				Y
26	7.40				Y
27	7.42				Y
28	7.42				Y
29	7.55				Y
30	7.51				Y
31	7.56				Y

No = N = Excursion) **Total N's** 4

**ENTRY POINT**

<<Have minimums been met for this day? **PWS ID: 41** 00536

**System Name:** NETARTS WATER DISTRICT

**Entry Point:** FIRST USER / 1000 Phelps AVE

**Sample Period:** DECEMBER / 2022  
Month/Year

**Number of excursions\* during this month:** 4  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.40

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** DAVID HANCOCK

**Signature:** *David Hancock*

**Date:** 01/04/2023

Send to DWP within 10 days after end of sampling period