

Day	pH	Alk	Phos	Other	Y/N
1	7.59				Y
2	7.54				Y
3	7.55				Y
4	7.59				Y
5	7.59				Y
6	7.62				Y
7	7.59				Y
8	7.63				Y
9	7.57				Y
10	7.72				Y
11	7.61				Y
12	7.57				Y
13	7.66				Y
14	7.62				Y
15	7.67				Y
16	7.70				Y
17	7.61				Y
18	7.60				Y
19	7.57				Y
20	7.58				Y
21	7.55				Y
22	7.61				Y
23	7.60				Y
24	7.62				Y
25	7.59				Y
26	7.51				Y
27	7.62				Y
28	7.55				Y
29	7.63				Y
30	7.53				Y
31	7.62				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00556

System Name: NETARTS WATER DISTRICT

Entry Point: FIRST USER

Sample Period: - 01/23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 4
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.40

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DAVID Hancock

Signature: David Hancock

Date: 02/02/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0