

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	7.60				Y
3	7.57				Y
4	7.69				Y
5	7.49	57			Y
6	7.40				Y
7	7.68				Y
8	7.82				Y
9	7.58				Y
10	7.50				Y
11	7.18				N
12	6.96				N
13	7.50				Y
14	7.52				Y
15	7.49				Y
16	7.51				Y
17	7.47				Y
18	7.57				Y
19	7.75				Y
20	7.72				Y
21	7.78				Y
22	7.81				Y
23	7.76				Y
24	7.74				Y
25	7.76				Y
26	7.65				Y
27	7.71				Y
28	7.72				Y
29	7.79				Y
30	7.83				Y
31					

(No = N = Excursion) Total N's **2**

<<Have minimums been met for this day?	County: Tillamook Agency: REGION 1
	<b>ENTRY POINT</b> EP-A PWS ID 4100556 NETARTS WATER DISTRICT
Sample period: <u>APRIL 2023</u> Month/Year	

Number of excursions during this month: 2  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference Minimum Water Quality Parameter(s) as set by State:	
pH	7.4
Alk	40.0 (Alkalinity)

Print Name: DAVID HANCOCK  
 Signature: *David Hancock*  
 Date & Phone#: 5/4/23 ~~9~~ 503-812-0322  
 Send to DWP within 10 days after end of sampling period