

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.77				N
2	7.74	42			N
3	7.70	40			N
4	7.76				N
5	7.65				N
6	7.76				N
7	7.79				N
8	7.76				N
9	7.79				N
10	7.79				N
11	7.77				N
12	7.78				N
13	7.68				N
14	7.75				N
15	7.76	40			N
16	7.78	40			N
17	7.76				N
18	7.77				N
19	7.76				N
20	7.81				N
21	7.85				N
22	7.76				N
23	7.75				N
24	7.74				N
25	7.78				N
26	7.81				N
27	7.79				N
28	7.83				N
29	7.81				N
30	7.82				N
31	7.81				N

<<Have minimums been met for this day?	County: Tillamook Agency: REGION 1
	<b>ENTRY POINT</b> <b>EP-A</b> <b>PWS ID 4100556</b> <b>NETARTS WATER DISTRICT</b>
Sample period: <u>MAY 2023</u> Month/Year	

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference	
<b>Minimum Water Quality Parameter(s) as set by State:</b>	
pH	7.4
Alk	40.0 (Alkalinity)

Print Name: DAVID B HANCOCK

Signature: [Signature]

Date & Phone#: 6/1/23 503.812.0322

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0