

NWD
(41-00556)

#3

Entry Point Monitoring Form



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80	47.88			Y
2	7.74				
3	7.83				
4	7.75				
5	7.75	47.8			
6	7.76	47.8			
7	7.73	47.8			
8	7.71				
9	7.76	41.27			
10	7.79				
11	7.76				
12	7.69				
13	7.81	54.7			
14	7.75				
15	7.72				Y
16	7.73	47.8			
17	7.77				
18	7.71				
19	7.71	47.8			
20	7.73	47.8			
21	7.70				
22	7.76				
23	7.65				
24	7.75				
25	7.79				
26	7.80	47.8			
27	7.64				
28	7.58				
29	7.62				
30	7.68				Y
31					

County: Tillamook Agency: REGION 1

ENTRY POINT
EP-A

PWS ID 4100556
NETARTS WATER DISTRICT

Sample period: JUNE/2023
Month/Year

Number of excursions during this month: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.4
 Alk 40.0 (Alkalinity)

Print Name: DAVID HANCOCK
 Signature: David Hancock
 Date & Phone#: 7/5/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 1