

Day	pH	Alk	Phos	Other	Y/N
1	7.56				
2	7.61				
3	7.67				
4	7.70				
5	7.62				
6	7.67	47.88			
7	7.68	54.42			
8	7.72				
9	7.72				
10	7.76				
11	7.71	47.88			
12	7.78				
13	7.72				
14	7.81				
15	7.71				
16	7.76				
17	7.72				
18	7.74				
19	7.80	47.88			
20	7.85	54.42			
21	7.89				
22	7.79				
23	7.88				
24	7.87				
25	7.80				
26	7.74	54.42			
27	7.79				
28	7.69				
29	7.74				
30	7.81				
31					

<<Have minimums been met for this day?

County: Tillamook Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100556**

**NETARTS WATER DISTRICT**

Sample period: September 2023  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.4  
 Alk 40.0 (Alkalinity)

Print Name: DAVID Hancock  
 Signature: [Signature]  
 Date & Phone#: 10/4/23 503 '812' 0322

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0