

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	
1	7.95	61.59				
2	7.82					
3	7.95					
4	7.93					
5	7.91	64.8	1 1			
6	7.91					
7	7.82		1 - 42 - 19			
8	7.91					
9	7,95			2.7		
10	7.95					
11	7.95	-				
12	7,91	61.59				
13	7.89					
14	7,82		7 4 1			
15	7.89					
16	7.87					
17	7.93					
18	7.93					
19	8.06	47.88		1.00		
20	7.99			19 4		
21	8,04					
22	7.93					
23	808					
24	7.86					
25	7.96					
26	7.81	6159				
27	7.54					
28	7.65					
29	7.62					
30						
31						
o = N = Excursion) Total N's						

< <have< th=""><th colspan="6">ENTRY POINT</th></have<>	ENTRY POINT					
been me this day?						
Syst	em Name: NETARTS WATER DISTRICT					
Entr	y Point: EP-A					
Sam	ple Period: February / 2024					
	Month/Year					
Number	of excursions* during this month:					
(Count th	e number of days when any WQP was					
less than	the minimum required)					
_						
Total exc	cursions during the previous 5 months:_					
(Over 9 e	excursions in 6 months is a violation. Entry					
Point and	Distribution excursions are cumulative)					
	For OHA use only					
	Minimum Water Quality					
	Parameters as set by					
	pH 7.40					
	Alk 40 (Alkalinity)					
	PO4 (Orthophosphate)					
	Other ( )					
D	wind Manage David of 1					

Print Name:	DAVID	B Han	coots
Signature: _			
Date: 03	15/24	0	
0 11 514	/		

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/